
25X1A2g

Approved For Release 1999/09/10 : CIA-RDP83-00423R001601180005-9

25X1A2g




Mettlen Substation near Lucerne, Switzerland.
161 kv bank circuit breaker. Breaker is
Cerlikon low oil content design.
161 kv cable termination is small brown
bushings behind circuit breaker and on
same structure with it.

25X1X6

Approved For Release 1999/09/10 : CIA-RDP83-00423R001601180005-9

SWITZERLAND LUZERN LUZERN (NW) 47 05 N 08 16 E Mettlen Substation. 220 kv switchgear. Brown-Boveri Airblast circuit BREAKER, CENTER. DERLIKON, LOW OIL CONTENT CIRCUIT BREAKER, RIGHT. APRIL




Mettlen Substation near Lucerne, Switzerland 220 kv switchgear - current and potential transformers,

Brown-Boveri airblast circuit breaker (with "M" on top) in center

Oerlikon - low oil content circuit breaker


(with red paint top and middle) at right.



Mettlen Substation near Lucerne, Switzerland. 230 kv double circuit construction, future 380 kv.

Note absence of deadend on line. Back of substation structure is guyed to take load.

25X1X6




Mettlen Substation near Lucerne, Switzerland r. High-voltage side of 100,000 kv bank (3 single-phase units).

230Y-171Y-27.56 delta kv, Brown-Boveri units.


Note radiators banked separate from transformer case.

25X1X6



Mettlen Substation near Lucerne, Switzerland
Three 100,000 kva banks, 230Y-171Y-27.56
delta (9 single-phase units)
171 kv connection is cable termination in:
transformer.
High-voltage bushing is 380 kv as banks can
be reconnected for this voltage.

High-voltage bushing is 380 kv as banks can be reconnected for this voltage. Tap changing under load in 171 kv winding. Brown-Boveri transformers. Note radiators banked separate from transformer case.



25X1X6

Mettlen Substation near Lucerne, Switzerland. 161/230 kv yard. Note guys on structure to carry line tension from opposite side.

Approved For Release 1999/09/10: CIA-RDP83-00423R001601180005-9

SWITZERLAND VALAIS ST. MAURICE (NR) 46 13 N 07 00 E LAVEY HYDROELECTRIC POWER PLANT. SECTION OF SWITCHYARD. APRIL 1954. CIA 142194

> Lavey Hydro Plant near St. Maurice, Switzerland, on Rhone River City of Lausanne System Part of Switchyard.



Lavey Hydro Plant near St. Maurice, Switzerland, on Rhone River City of Lausanne System Units installed in rock cavern. Taken

25X1X6

Approved For Release 1999/09/10 : CIA-RDP83-00423R001601180005-9

SHITZERLAND VALAIS ST. MAURICE (NE) 1/6 1/3 N 07 00 F LAVEY HYDROSLECTRIC POWER PLANT. DOUBLE CIRCUIT TRANSMISSION LINE AND SEC-Tion of switching structure. April (95). 100



Lavey Hydro Plant near St. Maurice, Switzerland, on Rhone River City of Lausanne System Double circuit transmission line and part 25X1X6 of switching structure.




West Melton Substation (Sheffield, Ting.)

Double Circuit - 275 kv twin conductor


line on left. 25X1X6



West Melton Substation (Sheffield, Eng.)
British Electricity Authority
New 275 kv Twin Conductor Line to Ferry
Bridge
Note reinforced concrete structure in
foreground. 25X1X6



West Melton Substation (Sheffield, Eng.)
British Electricity Authority
275 kv busses. Airblast circuit breaker
in background.



West Melton Substation (Sheffield, Eng.) / 275 kv switchgear - air blast circuit breaker.

Note use of reinforced concrete structures in place of steel.

Approved For F	ଣ୍ଟିଛିଞ୍ଜି (୨୭୭ /୦୭/10 : CIA-RDF	33-50423R00160118	0005-9 SECRET	
	ROUTING AND	CONTROL RECOR	D	
4	DO NOT DETACH FROM	i 'ON LOAN' DO	CUMENTS	
4	<u>6 Octol</u>	DATE		
	TO: GRAPHICS REGISTER		4	*
	ATTN:	. ROOM N		
	BUILDING	ROUPI N	v.	
	13 Black and White P	notographs		
	and		25X1A2g	
91		25X1A2g	- E	
	REMARKS		,	
		•	-	
	DOCUMENT(S) MUST	ON LOAN BE RETURNED TO	1	25X1A8a
	DOCUMENT(S) FOR RETENSION BY (DEADLINE) BY ADDRESSEE		V 9777 277	25X1A9a
	FROM:	RRANCH		25X1A8a
	BUILDING Quarters Eye	1808	extension (

Approved For Release 1999/09/10: CIA-RDP83-00423R001601180005-9 RESTRICTED